

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

June 25, 2008 RE-ISSUED 2/26/2009

NORWESCO, INC. ANASTASIA R. O'HARA PO BOX 439 ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE

Manufacturer: NORWESCO, INC. Product Name: SEPTIC TANK

Model Number(s): 1250

(53.5" L.L., 36" MAX. DEPTH OF BURY; 608 G.P.D. WHEN USED AS A SEPTIC TANK

BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)

Product File No: 20080318

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The manufacturer's manhole lid and eight inch pipe riser must be installed on one of the manholes to provide an inspection opening.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent
 quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220
 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.

This approval supersedes the approval issued on 5/9/2007 under product file number 20070191. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070191.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST

Engineering Consultant--Plumbing Product Reviewer

Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov

SBD-10564-E (N.10/97) File Ref: 08031804.DOC